

REGIONAL WATER TESTING LAB, HOSHIARPUR

Government ITI, Jalandhar Road, Hoshiarpur
rwtlhsp@gmail.com

To,

Akal Academy, Khera
V.P.O. Khera, Sub Tehsil Mahilpur, Distt. Hoshiarpur

No.: RWTLHSP/2425/00052 Dated : 30/04/2024

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. AAK/24/225 Dated: 23/04/2024

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 23/04/2024. It is request to fill the attached feedback form and send it back to Regional Water Testing Lab, Hoshiarpur

D/A : Test Report



**Authorized Signatory
For, Regional Water Testing Lab
Hoshiarpur**

REGIONAL WATER TESTING LAB, HOSHIARPUR

Government ITI, Jalandhar Road, Hoshiarpur
rwtlhsp@gmail.com

TEST REPORT

Name & Address of Customer : Akal Academy, Khera V.P.O. Khera, Sub Tehsil Mahilpur, Distt. Hoshiarpur		Customer Reference No.	No : AAK/24/225 Dated : 23/04/2024
		Sample Submitted by	Harman Singh
		Date of Sample Receipt	23/04/2024
		Analysis Starting Date	29/04/2024
		Analysis completion Date	30/04/2024
Discipline : Bacteriological Testing		Group: Water	
ULR No.:		Sample Type :	Water
Test Report No.:	RWTLHSP/2425/00052	Date of Issue :	30/04/2024
Registration no.:	RWTLHSP/REG2425/00175	Condition of Sample :	Unsealed
Collection Point:	Treatment Plant (RO/CWPP/ARP/HH Purifier)	Quantity/Type of Bottle:	1000 ml / Amber Coloured Sample Bottle - 500 mL.
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	Akal Academy, Khera / NA
Village :	Khera	Habitation :	Khera
Block:	Mahilpur	District :	Hoshiarpur
Latitude :	Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	Total Coliform(TC)	ND	Shall not be detectable in any 100 ml sample	No relaxation	MPN/100 ml.	IS-1622 MPN Method
2	E-Coli	ND	Shall not be detectable in any 100 ml sample	No relaxation	MPN/100 ml.	IS-1622 MPN Method
3	Bacteriological Contamination(B)	Absent			--	H2S Vial

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By



Abhishek Joshi
Sr. Chemist
Authorized Signatory
For,Regional Water Testing Lab
Hoshiarpur

----- End of the Test Report -----

Sub Divisional Engineer, W/S & Sanitation Sub Division, Mahilpur.

Telephone No. 01884-246073

e-mail: sdews.mpur@yahoo.com

To,

Head Manistress,
Akai Acadmy Khera,
Vill. Khera Tehsil Mahilpur Distt.Hoshiarpur (PB),

No. 742 Date: 8/5/24

Sub: Health & Sanitary Condition Certificate.

On inspection of your Academy premises by the our department. Sanitary conditions in the academy were found Satisfactory. Water samples found potable as per the report of Regional Water Testing Lab. Hoshiarpur vide Sample No. RWTLHSP/2425/00052 Date 30.04.2024

Sub Divisional Engineer,
W/S & Sanitation S/D,
Mahilpur.